

Corrigendum

of 19 December 2023

to Annex I and Annex Ia of Recommendation 03-2023 on reasoned proposals for amendments to the network codes on requirements for grid connection of generators and on demand connection

In Annex I, Article 20(4):

for: ‘4. With regard to grid forming capability:

- (a) type B power park modules connected at 110 kV level or above shall fulfil the requirements laid down in Article Y(6) and (Error! Reference source not found.) and paragraph 5 of this Article;
- (b) type B power park modules of Pmax of 10 MW or above, which are connected below the 110 kV level to a feeder dedicated to one or more power park modules connected to a substation with transformation to 110 kV or above, shall fulfil the requirements laid down in Article Y(6) and (Error! Reference source not found.) and paragraph 5 of this Article;
- (c) with regard to grid forming capability of type B power park modules other than in points Error! Reference source not found. and Error! Reference source not found. above, Article Y(6) and (Error! Reference source not found.) and paragraph 5 of this Article are applicable, taking into consideration the provisions of Article Y(5).’

read: ‘4. With regard to grid forming capability:

- (a) type B power park modules connected at 110 kV level or above shall fulfil the requirements laid down in Article Y(6) and (7) and paragraph 5 of this Article;
- (b) type B power park modules of Pmax of 10 MW or above, which are connected below the 110 kV level to a feeder dedicated to one or more power park modules connected to a substation with transformation to 110 kV or above, shall fulfil the requirements laid down in Article Y(6) and (7) and paragraph 5 of this Article;
- (c) with regard to grid forming capability of type B power park modules other than in points (a) and (b) above, Article Y(6) and (7) and paragraph 5 of this Article are applicable, taking into consideration the provisions of Article Y(5).’

In Annex I, Article 21(4):

for: ‘4. With regard to grid forming capability:

- (a) type C power park modules connected at 110 kV level or above shall fulfil the requirements laid down in Article Y(6) and (Error! Reference source not found.) and paragraph 5 of this Article;

(b) type C power park modules of Pmax of 10 MW or above, which are connected below the 110 kV level to a feeder dedicated to one or more power park modules connected to a substation with transformation to 110 kV or above, shall fulfil the requirements laid down in Article Y(6) and (Error! Reference source not found.) and paragraph 5 of this Article;

(c) with regard to grid forming capability of type C power park modules other than in points (a) and (b) above, Article Y(6) and (Error! Reference source not found.) and paragraph 5 of this Article are applicable, taking into consideration the provisions of Article Y(5).'

read: '4. With regard to grid forming capability:

(a) type C power park modules connected at 110 kV level or above shall fulfil the requirements laid down in Article Y(6) and (7) and paragraph 5 of this Article;

(b) type C power park modules of Pmax of 10 MW or above, which are connected below the 110 kV level to a feeder dedicated to one or more power park modules connected to a substation with transformation to 110 kV or above, shall fulfil the requirements laid down in Article Y(6) and (7) and paragraph 5 of this Article;

(c) with regard to grid forming capability of type C power park modules other than in points (a) and (b) above, Article Y(6) and (7) and paragraph 5 of this Article are applicable, taking into consideration the provisions of Article Y(5).'

In Annex Ia, Article 20(4):

for: '4. With regard to grid forming capability:

(a) type B power park modules connected at 110 kV level or above shall fulfil the requirements laid down in Article Y(6) and (Error! Reference source not found.7) and paragraph 5 of this Article;

(b) type B power park modules of Pmax of 10 MW or above, which are connected below the 110 kV level to a feeder dedicated to one or more power park modules connected to a substation with transformation to 110 kV or above, shall fulfil the requirements laid down in Article Y(6) and (Error! Reference source not found.7) and paragraph 5 of this Article;

(c) with regard to grid forming capability of type B power park modules other than in points Error! Reference source not found.(a) and Error! Reference source not found.(b) above, Article Y(6) and (Error! Reference source not found.7) and paragraph 5 of this Article are applicable, taking into consideration the provisions of Article Y(5).'

read: '4. With regard to grid forming capability:

(a) type B power park modules connected at 110 kV level or above shall fulfil the requirements laid down in Article Y(6) and (7) and paragraph 5 of this Article;

- (b) type B power park modules of Pmax of 10 MW or above, which are connected below the 110 kV level to a feeder dedicated to one or more power park modules connected to a substation with transformation to 110 kV or above, shall fulfil the requirements laid down in Article Y(6) and (7) and paragraph 5 of this Article;
- (c) with regard to grid forming capability of type B power park modules other than in points (a) and (b) above, Article Y(6) and (7) and paragraph 5 of this Article are applicable, taking into consideration the provisions of Article Y(5)'

In Annex Ia, Article 21(4):

for: '4. With regard to grid forming capability:

- (a) type C power park modules connected at 110 kV level or above shall fulfil the requirements laid down in Article Y(6) and (Error! Reference source not found.7) and paragraph 5 of this Article;
- (b) type C power park modules of Pmax of 10 MW or above, which are connected below the 110 kV level to a feeder dedicated to one or more power park modules connected to a substation with transformation to 110 kV or above, shall fulfil the requirements laid down in Article Y(6) and (Error! Reference source not found.7) and paragraph 5 of this Article;
- (c) with regard to grid forming capability of type C power park modules other than in points (a) and (b) above, Article Y(6) and (Error! Reference source not found.7) and paragraph 5 of this Article are applicable, taking into consideration the provisions of Article Y(5)'

read: '4. With regard to grid forming capability:

- (a) type C power park modules connected at 110 kV level or above shall fulfil the requirements laid down in Article Y(6) and (7) and paragraph 5 of this Article;
- (b) type C power park modules of Pmax of 10 MW or above, which are connected below the 110 kV level to a feeder dedicated to one or more power park modules connected to a substation with transformation to 110 kV or above, shall fulfil the requirements laid down in Article Y(6) and (7) and paragraph 5 of this Article;
- (c) with regard to grid forming capability of type C power park modules other than in points (a) and (b) above, Article Y(6) and (7) and paragraph 5 of this Article are applicable, taking into consideration the provisions of Article Y(5)'
